

1021 West Baraga Avenue,  
Marquette, Michigan 49855  
Phone (906) 228-4480 Fax (906) 228-7524

8571 W. Grand River Ave., Suite 600  
Brighton, Michigan 48816  
Phone: (810) 229-2701 Fax: (810) 229-6767

---

Field Report No:	3 – Civil	Project:	Beal City
Date:	7/14/21	Time:	2:00 pm
Project No.:	20-918	Report By:	Andrew Mansfield
Est. % Complete:	10%	Weather:	Sunny
Temperature Range:	~85°	Conformance to Schedule:	

---

Observations:

The concrete contractor was also on-site pouring the remainder of the foundations for the Elementary School addition. The previous day's pour was inspected and overall looked good. The foundation for the High School was complete and backfilled ready for block. I spoke with Clinton Clark from Wolgast and the plan is to start setting the first course of block next so that they can pour the floors. The state inspector (Scott Wilmont) was also on-site inspecting the previous day's foundation pour and approved backfilling which the contractor expects to start tomorrow.

Malley Construction was on-site grading and rolling the western half of the parking lot. In addition, they began proof-rolling the parking lot to look for soft spots and other than the backfilled areas where there used to be light poles, everything was looking good.

PSI was on-site testing concrete and inspecting the proof-roll on the western half of the parking lot.

Soil erosion measures are in place and are in fairly good condition.

See civil site pictures (22) in folder F:\20-918 Beal City Bond\Construction\Field reports\Civil\Site Visit 7-14-21.

---